


**CEE-LOCK PANEL
ASTM**



MID AMERICA TESTING LABORATORY, INC.

10525 SIGNAL HILL DRIVE • CATAWISSA, MISSOURI 63015
(636) 257-4722 • FAX (636) 257-5425

DATE OF REPORT: October 1, 2001

LOCATION OF TEST: Mid America Testing Laboratory

DATES OF ERECTION: February 21, 2001 & July 18, 2001

DATES OF TESTING: February 22, 2001 & July 18, 2001

PANEL IDENTIFICATION: Cee-lock Panel System (with Vinyl Insert)

PROJECT NUMBER: 01016L

CLIENT: Berridge Manufacturing Company

The following were present for all or portions of the erection and testing.

Mr. Bobby Marks, Jr.	Berridge Manufacturing Company
Mr. Tim Ponting	Mid America Testing Laboratory
Mr. Travis Swissheim	Mid America Testing Laboratory
Mr. Rick Heitmann	Mid America Testing Laboratory

INTRODUCTION

As requested, Mid America Testing Laboratory performed weatherization and structural testing on the Cee-lock Panel System as fabricated and installed by Berridge Manufacturing. The panel was installed onto a testing chamber, which allowed visual viewing of the underside of the panel during the water infiltration testing. The test panel measured a nominal 3'3" wide and incorporated three (3) standing seams with a dimension between seams at 1'4 1/2". The overall length of the test specimen was 6'. All tests were conducted with the panel in a horizontal position.

FORMAL TESTING

All tests were conducted on the specimen identified above utilizing typical ASTM standards.

Page 2
Cee-lock Panel System with Vinyl Insert
01016L
October 1, 2001

1. **PRELOAD** +45.0 PSF static pressure (50% of the positive design load for 10 seconds).

ALLOWED: No failure of the system

RESULTS: No failure of the system

The above result constitutes an acceptable performance.

2. **PRELOAD** -45.0 PSF static pressure (50% of the positive design load for 10 seconds).

ALLOWED: No failure of the system

RESULTS: No failure of the system

The above result constitutes an acceptable performance.

3. **STATIC AIR INFILTRATION** (ASTM E 283) at 6.24 PSF (50 MPH wind and 1.2" H₂O).

ALLOWED: Air infiltration shall not exceed 1.1 CFM gross leakage.

RESULTS: The specimen measured .2 CFM gross leakage.

The above results constitute an acceptable performance.

4. **STATIC AIR INFILTRATION** (ASTM E 331) at 6.24 PSF (50 MPH wind and 1.2" H₂O).

ALLOWED: No uncontrolled water or visible water to the underside of the roof panel shall be allowed.

RESULTS: No uncontrolled water or visible water at the completion of the testing was noted.

The above results constitute an acceptable performance.

Page 3
Cee-lock Panel System with Vinyl Insert
01016L
October 1, 2001

5. **STATIC WATER INFILTRATION** (ASTM E 331) at 10.0 PSF (63 MPH wind and 1.92" H₂O) with a water spray rate of five (5) gallons per hour per square foot minimum for fifteen (15) minutes.

ALLOWED: No uncontrolled water leakage to the room side shall be allowed.

RESULTS: No uncontrolled water leakage was noted to the room side.

The above result constitutes an acceptable performance.

6. **STATIC WATER INFILTRATION** (ASTM E 331) at 12.0 PSF (69 MPH wind and 2.3" H₂O) with a water spray rate of five (5) gallons per hour per square foot minimum for fifteen (15) minutes.

ALLOWED: No uncontrolled water leakage to the room side shall be allowed.

RESULTS: No uncontrolled water leakage was noted to the room side.

The above result constitutes an acceptable performance.

7. **STATIC WATER INFILTRATION** (ASTM E 331) at 15.0 PSF (77 MPH wind and 2.88" H₂O) with a water spray rate of five (5) gallons per hour per square foot minimum for fifteen (15) minutes.

ALLOWED: No uncontrolled water leakage to the room side shall be allowed.

RESULTS: No uncontrolled water leakage was noted to the room side.

The above result constitutes an acceptable performance.

Page 4
Cee-lock Panel System with Vinyl Insert
01016L
October 1, 2001


SUMMARY:

As can be determined by this brief report, the Cee-lock Panel System has met or exceeded the test criteria to which it was subjected. In addition to the ASTM E 283 and ASTM E 331 methods, which were specifically identified, the unit has also met or exceeded ASTM E 1680 and ASTM E 1646 for air and moisture testing.

Should you have any questions regarding the information contained in this report, please feel free to contact the writer.

Respectfully Submitted,

Mid America Testing Laboratory



Rick A. Heltmann
President

RAH/slh
01016LTR